

Luz



The luminaire should be positioned so that prolonged staring into the luminaire at a distance closer than 0.756m is not expected.

IP66 CE UK CA

WINDAGE - 0.14m²

	KG
SINGLE	≈10.5
TWIN	≈10.7
QUAD	≈11.0



Disconnect luminaire from the supply when conducting in-situ insulation resistance testing.



If the external flexible cable or cord of this luminaire is damaged, it shall be exclusively replaced by the manufacturer or his service agent or a similar qualified person in order to avoid a hazard.



